



Illinois Environmental Protection Agency

Bureau of Water • 1021 North Grand Avenue East • P.O. Box 19276 • Springfield • Illinois • 62794-9276

Division of Water Pollution Control

Municipal Lagoon Wastewater Review Sheet

General Permit For Municipal Lagoon Wastewater Facilities

Reviewer: Getie Yilma Date: 10/27/2014

Permit Number: ILG580227

Applicant Name: Village of Versailles

Mailing Address: P.O. Box 327

City: Versailles State: Illinois Zip Code: 62378

Facility Name: Village of Versailles - STP County: Brown

Facility Address: West 2nd Street

City: Versailles State: Illinois Zip Code: 62378

Existing Facility: ☒ Yes ☐ No (If no, facility is not eligible for coverage under the general permit)

New Outfall or Increase Loading: ☐ Yes ☒ No (If yes, facility is not eligible for coverage under the general permit)

Non-Publicly Owned < 2,500 P.E.
(ILG551):

☐

Publicly Owned < = 2,500 P.E.
(ILG580):

☒

Publicly Owned and > 2,500 P.E. < =
5,000 P.E. (ILG582):

☐

Domestic Lagoon: ☒ Yes ☐ No

Combined Sewer Overflows:
(if yes, not eligible) ☐ Yes ☒ No

Single Pipe Discharge:
(if no, not eligible) ☒ Yes ☐ No

Environmental Justice Area: ☐ Yes ☒ No

Operation by Class 4 Operator: ☒ Yes ☐ No

Approval TMDL: ☐ Yes ☒ No

Does the TMDL require further
Permit Limit(s): ☐ Yes ☐ No ☒ NA (if yes, facility is not eligible for coverage under the
general permit)

7Q10: 0 cfs

Dilution Ratio > 5:1: ☐ Yes ☒ No

Lagoon Exemption Date: 3/19/1980

Date of Year-Round Disinfection Exemption: 12/22/1994

Applicable Permit Page: ☐ Page 2 ☒ Page 3

Receiving Stream is on the 303(d) list: ☐ Yes ☒ No

(if yes, potential causes):	
uses impaired:	

Outfall Num.	Receiving Stream	Latitude			Longitude			General Use or Secondary Contact	Average Flow (MGD)	Maximum Flow (MGD)
001	Russett Branch	39°	53'	12"	90°	39'	48"	General Use	0.0563	0.14